

JC SURVEY
LAND SURVEYING

August 3, 2015

Ms. Kim Bantle
PALISAIR HOA


Re: Project located at 16100 Anoka Drive in Los Angeles, CA

Dear Ms. Bantle:

I do hereby certify that I have performed a survey of the site and measured the highest constructed point of the finished slab (floor/FF) for the proposed structure (currently under construction) to be at the elevation of 491.50 per site datum. The plans show the elevation of the finished slab (floor/FF) to be 491.20. By subtraction, the existing conditions are 0.30 vertical feet higher than the plan.

If there are any additional questions regarding this project, please contact our office at your convenience.

Sincerely,


Justin Coons, PLS 8790
JC Survey

